



SEE STANDARD WAT-07 FOR  
TYPICAL 3/4" METER INSTALLATION

**DETAIL "A"**

IRON PIN AT LOT CORNER

3' MIN- 4' MAX  
FROM FACE OF CURB

NOTE:  
AREAS WHERE STATIC PRESSURES  
ARE BELOW 60 PSI, SERVICE LINE  
UNDER THE STREET SHALL BE  
1 1/4" DIAMETER.

NOTE:  
ODOT TYPE "A"  
AGGREGATE FROM  
TOP OF PIPE TO  
BASE

REVISION	BY	DATE	<b>LONG WATER SERVICE (SINGLE)</b>	
			STANDARD DETAILS	
			CITY OF OWASSO, OKLAHOMA	
			PUBLIC WORKS DEPARTMENT	
			ENGINEERING DIVISION	
			DATE: 05/05	STANDARD NO. WAT-04