



CURB LINE

3/4"X3/4"X1" TEE

4' (TYP)

SEE STANDARD WAT-07 FOR TYPICAL 3/4" METER INSTALLATION

DETAIL "A"

IRON PIN AT LOT CORNER

3' MIN- 4' MAX FROM FACE OF CURB

NOTE:
AREAS WHERE STATIC PRESSURES ARE BELOW 60 PSI, SERVICE LINE UNDER THE STREET SHALL BE 1 1/4" DIAMETER.

NOTE:
ODOT TYPE "A"
AGGREGATE FROM
TOP OF PIPE TO
BASE

REVISION	BY	DATE	LONG WATER SERVICE (DOUBLE)	
			STANDARD DETAILS	
			CITY OF OWASSO, OKLAHOMA	
			PUBLIC WORKS DEPARTMENT	
			ENGINEERING DIVISION	
			DATE: 05/05	STANDARD NO. WAT-05