



NOTE:
 THE LOOPED LINE SHALL BE A MINIMUM 4" DIAMETER. LINES THAT SERVICE A FIRE HYDRANT SHALL BE A MINIMUM 6" DIAMETER.

REVISION	BY	DATE	WATERLINE AT CUL-DE-SAC	
			STANDARD DETAILS	
			CITY OF OWASSO, OKLAHOMA	
			PUBLIC WORKS DEPARTMENT	
			ENGINEERING DIVISION	
			DATE: 05/05	STANDARD NO. WAT-11