



O.S.H.A. APPROVED LADDER W/ APPROVED EXTENSION. LADDER TO HAVE CLEAR ACCESS FROM DOOR.



LADDER TO HAVE CLEAR ACCESS FROM VAULT LID.

**PLAN**

VAULT DOOR, SEE NOTE 2



**ELEVATION**

**NOTE:**

1. FINISH GRADE SHALL SLOPE AWAY FROM THE VAULT COVER SO AS TO PREVENT PONDING.
2. VAULT DOOR MECHANISMS SHALL NOT PROJECT BELOW THE CEILING OF THE VAULT INTERIOR. THE VAULT DOOR SHALL HAVE A 1 5/16" Ø HOLE FOR THE AUTO READ ASSEMBLY.

REVISION	BY	DATE	<b>3" OR LARGER METER VAULT</b> STANDARD DETAILS	
			CITY OF OWASSO, OKLAHOMA	
			PUBLIC WORKS DEPARTMENT	
			ENGINEERING DIVISION	
			DATE: 05/05	STANDARD NO. WAT-15