



PIPE BEDDING

NON-PAVED AREAS	PAVED AREAS
EXCAVATED MATERIAL	CRUSHED ROCK
SELECT FILL	CRUSHED ROCK
ODOT AGG. BASE TYPE A OR SCREENING	ODOT AGG. BASE TYPE A OR SCREENING
SCREENINGS	SCREENINGS

NOTES:

1. SELECT FILL CONSISTS OF EXCAVATED MATERIALS CONTAINING NO ROCKS LARGER THAN 2 INCHES.
2. CRUSHED ROCK SHALL BE ODOT TYPE "A" BASE AGGREGATE
3. COMPACTION REQUIREMENTS:
 - a. NON- PAVED AREAS: 90% MAXIMUM STANDARD PROCTOR DENSITY FOR COHESIONLESS SOILS AND 85% FOR COHESIVE SOILS.
 - b. PAVED AREAS: 95% MAXIMUM STANDARD PROCTOR DENSITY FOR COHESIONLESS SOILS.
4. FILLS OVER 10 FEET DEEP - INITIAL BACKFILL SHALL BE ODOT TYPE "A" BASE AGG.
5. FLOWABLE FILL MAY BE SUBSTITUTED FOR TYPE "A" AGGREGATE IN ROAD CROSSING.
6. IN AREAS WERE WATER INFILTRATION CANNOT BE CONTROLLED, BEDDING AND INITIAL BACKFILL SHALL BE MATERIAL CONFORMING TO ODOT SECTION 703.04(A).

:STANDARD DETAIL:STORMSTRM-01

REVISION	BY	DATE	STORM SEWER PIPE INSTALLATION	
			STANDARD DETAILS	
			CITY OF OWASSO, OKLAHOMA	
			PUBLIC WORKS DEPARTMENT	
			ENGINEERING DIVISION	
			DATE: 05/05	STANDARD NO. STRM-01