



NOTES:

1. MINIMUM PERFORATED PIPE SIZE IS 4" DIAMETER.
2. PERFORATED PIPES SHALL BE TIED TO THE STORM SEWER SYSTEM.
3. ON STREETS WITH CURB AND GUTTER, THE DRAIN SHALL BE OUTSIDE BUT ADJACENT TO THE CURB.
4. PIPE MATERIAL SHALL BE POLYETHYLENE PIPE THAT MEETS ASTM F405 SPECIFICATIONS.

REVISION	BY	DATE	PAVING BASE DRAINAGE STANDARD DETAILS	
			DATE: 05/05	STANDARD NO. STRT-23